



**GOVERNMENT OF KARNATAKA**  
**Public works Department**

**BUILDING SAFETY CERTIFICATE**  
**APPNEDIX-XI**

No: AEE:PWD:No.2: NSD:Bldg Safety: 30 : 2024-25

Dated: 08/05/2024

Certified that the existing building **Gopalan National School North at No.79, Kondashetty halli Road, Mavallipura, Hesaghatta Hobli, Bengaluru- 560 089** comprised of Partly Basement floor, Ground floor + 1 upper floor owned/occupied by **Gopalan Foundation (R), No.05, Richmond Road Bangalore - 560 025**, have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers of Public Works Department, Government of Karnataka on 04-05-2024 in the presence of **Mrs. Savitha Suresh, Principal**, Gopalan National School North, No.79, Kondashetty halli Road, Mavallipura, Hesaghatta Hobli, Bengaluru- 560 089 and certified that the building/premises is fit for occupancy upto classes Nursery to Grade 7 with effect from 06.05.2024 for a period of One year in accordance with rule and subject to compliance of the specific conditions as appended.

- Safety measures to be adopted to prevent movement of students at terrace and measures to be taken to fix safety grills at necessary places.
- Water proofing work at toilets and terrace to be completed and cracks to be filled with suitable sealants.
- All Exposed Dummy columns Concrete and Steel at the terrace to be properly restored to good condition and steel painted with anti corrosive paint.
- General periodical maintainance for over all building.
- Any modifications, Addtions & Alterations must be carried out under strict technical guidance and supervision after obtaining all necessary approvals from the competent authorities.

Issued on 06.05.2024 at Bangalore by Assistant Executive Engineer, PWD, No.2, North Sub-Division, K.R. Circle, Bangalore-560 001.

(B. Venkatesh)

**Asst. Executive Engineer**

**No. 2, PWD North Sub-Division**  
**Bangalore - 560 001**